



Safety Message of the Day for IMEA Members



Protective Grounding Safety Message APPA Safety Manual 17th Edition

Paragraph 514.1 Overhead

- a) Temporary protective grounds shall be placed at such locations and arranged in such a manner as to prevent each employee from being exposed to hazardous differences in electrical potential
- b) Equipotential grounding is required whenever possible. If an equipotential zone cannot be established at the worksite and bracket grounding is utilized, rubber gloves and other appropriate personal protective equipment shall be required.