

Safety Message of the Day for IMEA Members



OSHA Series Safety Message 1910.269(I)(2) At least two employees.

1910.269(I)(2)(i)

Except as provided in paragraph (I)(2)(ii) of this section. NOTE: (A), (B), & (C) Below are when you can work alone

Paragraph (I)(2)(i) of this section does not apply to the following operations:

1910.269(I)(2)(ii)(A)

Routine circuit switching, when the employer can demonstrate that conditions at the site allow safe performance of this work,

1910.269(I)(2)(ii)(B)

Work performed with live-line tools when the position of the employee is such that he or she is neither within reach of, nor otherwise exposed to contact with, energized parts, and

1910.269(I)(2)(ii)(C)

Emergency repairs to the extent necessary to safeguard the general public.