



Safety Message of the Day for IMEA Members



OSHA Standards Safety Message

1910.269(n)(3)

Equipotential zone. Temporary protective grounds shall be placed at such locations and arranged in such a manner that the employer can demonstrate will prevent each employee from being exposed to hazardous differences in electric potential.

Note to paragraph (n)(3): Appendix C to this section contains guidelines for establishing the equipotential zone required by this paragraph. The Occupational Safety and Health Administration will deem grounding practices meeting these guidelines as complying with paragraph (n)(3) of this section.

<https://www.osha.gov/laws-regs/regulations/standardnumber/1910/1910.269AppC>